

From
District Collector,
Kanniyakumari District,
at Nagercoil.

To
Thiru. J.R. Julius,
No. 4A1, St. Antony Street,
Thalavaipuram.
Nagercoil - 629004.

E1/8882/14, dated: 23.09.2014

Sir,

Sub : Inclusion of the name of Private Practising
Engineer class IA in Kanniyakumari District -
informed - Regarding.

Ref : 1. Your application dated: 05.03.14
2. Engineer-in-Chief(Buildings), Chief
Engineer(Buildings) Chennai Region,
Chief Engineer(Gen) PWD, Chennai Letter
No.AEE/T1/AE III/31520/14, dated 11.07.14

It is here by informed that your name has been included in the
panel of Private Practising Engineer under class IA (one-A) Category
(Buildings, the cost of which exceeds Rupees 50 Lakhs) in
Kanniyakumari District as per Engineer-in-Chief(Buildings), Chief
Engineer(Buildings) Chennai Region, Chief Engineer(Gen) PWD,
Chennai letter in the vide reference 2nd cited.

Sd/- S.Ramachandran,
For Collector,
Special Deputy Collector (SSI)

// True copy // by order //


Head Assistant (E)


J.R.JULIUS , M.E., Ph.D., MIE, FIV,		Phone : 04652 - 261144 Mobile : 94434 14477 98423 14477 email : jrjulus1970@gmail.com
Registered Valuer	District Panel Engineer	Chartered Engineer
• Plans	• Estimates	• Valuations
		• Stability Certificates
4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.		

S.C. No. 09/2026

Date: 12.01.2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : 12-305/6 (Block C)
2. Location of the building : Thyrambika Vidya Mandir (Kinder World),
R.S.No. 463/2A1B,2A2,2A3,3A,
467/3,4C2,4D,4E,4F,6D,6E,6F,7D,7E,7F,7G,8B
Cherupaloor, Kulasekaram Post, Kanyakumari District.
3. Year of construction : 2025
4. Approximate cost of constn.
as per current rates : 250 Lakhs
5. Purpose for which building is
being used/ proposed to be used : School Building
6. Purpose for which building has
hitherto been used : School Building
7. Details of construction of building
 - a. Foundation : RCC Footing
 - b. Basement : RCC Plinth beam
 - c. Super Structure : RCC Columns with panel Brick Wall
 - d. Floor : PCC & Vitrified Tile floor finish
 - e. Roof : R.C.C. slab & beams
8. Period for which license
is required : 01.02.2026 to 31.01.2029 (3 years)
9. Number of persons to be
accommodated : 800 Nos.



 J.R.Julius
 District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.


 Signature of the building owner

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 29.71 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R.Julius
District Panel Engineer

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
D.No.12-305/6, Block C, Thyrayambika Vidya Mandir, Cherupaloor, Kulasekaram Post, Kanyakumari District.	1 year	250 Lakhs	GF+3 only	Framed structure with paneled brick wall	School Building	01.02.2026 to 31.01.2029 (3 years)	800 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.



 J.R. Julius

 District Panel Engineer

FORM C

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 29.71 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R.Julius
District Panel Engineer

J.R.JULIUS , M.E., Ph.D., MIE, FIV,		Phone : 04652 - 261144 Mobile : 94434 14477 98423 14477 email : jrjulus1970@gmail.com
Registered Valuer	District Panel Engineer	Chartered Engineer
• Plans	• Estimates	• Valuations
		• Stability Certificates
4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.		

S.C. No. 05/2026

Date: 12.01.2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : 12-305/2 (L.K.G. Block)
2. Location of the building : Thyrambika Vidya Mandir,
R.S.No. 467/10, Cherupaloor,
Kulasekaram Post, Kanyakumari District.
3. Year of construction : 2018
4. Approximate cost of constn.
as per current rates : 60 Lakhs
5. Purpose for which building is
being used/ proposed to be used : School Building
6. Purpose for which building has
hitherto been used : School Building
7. Details of construction of building
 - a. Foundation : RCC Footing
 - b. Basement : RCC Plinth beam
 - c. Super Structure : RCC Columns with panel Brick Wall
 - d. Floor : PCC & Vitrified Tile floor finish
 - e. Roof : R.C.C. slab & beams
8. Period for which license
is required : 01.02.2026 to 31.01.2029 (3 years)
9. Number of persons to be
accommodated : 180 Nos.



J.R.Julius
District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.


Signature of the building owner

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 23.17 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1½:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1½:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)




J.R.Julius
District Panel Engineer

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
D.No.12-305/2, L.K.G. Block, Thyrayambika Vidya Mandir, Cherupaloor, Kulasekaram Post, Kanyakumari District.	8 years	60 Lakhs	GF+1 only	Framed structure with paneled brick wall	School Building	01.02.2026 to 31.01.2029 (3 years)	180 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.



J.R.Julius
District Panel Engineer

FORM C

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION


1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 23.17 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R.Julius
District Panel Engineer

J.R.JULIUS , M.E., Ph.D., MIE, FIV,		Phone : 04652 - 261144 Mobile : 94434 14477 98423 14477 email : jrjulius1970@gmail.com
Registered Valuer	District Panel Engineer	Chartered Engineer
• Plans	• Estimates	• Valuations
• Stability Certificates		
4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.		

S.C. No. 06/2026

Date: 12.01.2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : 12-305/3 (Administrative Block)
2. Location of the building : Thyrambika Vidya Mandir,
R.S.No. 467/8, Cherupaloor,
Kulasekaram Post, Kanyakumari District.
3. Year of construction : 2018
4. Approximate cost of constn.
as per current rates : 160 Lakhs
5. Purpose for which building is
being used/ proposed to be used : School Building
6. Purpose for which building has
hitherto been used : School Building
7. Details of construction of building
 - a. Foundation : RCC Footing
 - b. Basement : RCC Plinth beam
 - c. Super Structure : RCC Columns with panel Brick Wall
 - d. Floor : PCC & Cement floor finish
 - e. Roof : R.C.C. slab & beams
8. Period for which license
is required : 01.02.2026 to 31.01.2029 (3 years)
9. Number of persons to be
accommodated : 800 Nos.



J.R. Julius
District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Signature of the building owner

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 28.17 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)


J.R.Julius
District Panel Engineer

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
D.No.12-305/3, Administrative Block, Thyrayambika Vidya Mandir, Cherupaloor, Kulasekaram Post, Kanyakumari District.	8 years	160 Lakhs	BF + GF+1 only	Framed structure with paneled brick wall	School Building	01.02.2026 to 31.01.2029 (3 years)	800 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.



J.R. Julius
District Panel Engineer

FORM C

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 28.17 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R. Julius
District Panel Engineer


J.R.JULIUS , M.E., Ph.D., MIE, FIV,		Phone : 04652 - 261144 Mobile : 94434 14477 98423 14477 email : jrjulus1970@gmail.com
Registered Valuer	District Panel Engineer	Chartered Engineer
• Plans	• Estimates	• Valuations
		• Stability Certificates
4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.		

S.C. No. 07/2026

Date: 12.01.2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : 12-305/4 (Main Block) - Block A
2. Location of the building : Thyrambika Vidya Mandir,
R.S.No. 463/2A3,3A,467/4Cpt,4D,6D, Cherupaloor,
Kulasekaram Post, Kanyakumari District.
3. Year of construction : 2018
4. Approximate cost of constn.
as per current rates : 400 Lakhs
5. Purpose for which building is
being used/ proposed to be used : School Building
6. Purpose for which building has
hitherto been used : School Building
7. Details of construction of building
 - a. Foundation : RCC Footing
 - b. Basement : RCC Plinth beam
 - c. Super Structure : RCC Columns with panel Brick Wall
 - d. Floor : PCC & Cement floor finish
 - e. Roof : R.C.C. slab & beams
8. Period for which license
is required : 01.02.2026 to 31.01.2029 (3 years)
9. Number of persons to be
accommodated : 800 Nos.



J.R.Julius
District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Signature of the building owner

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION


1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 31.86 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)


J.R.Julius
District Panel Engineer

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
D.No.12-305/4, (Main Block), Block A, Thyrayambika Vidya Mandir, Cherupaloor, Kulasekaram Post, Kanyakumari District.	8 years	400 Lakhs	BF + GF+2 only	Framed structure with paneled brick wall	School Building	01.02.2026 to 31.01.2029 (3 years)	1280 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.



J.R.Julius
District Panel Engineer

FORM C

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION


1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 31.86 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R. Julius
District Panel Engineer

J.R.JULIUS , M.E., Ph.D., MIE, FIV,		Phone : 04652 - 261144 Mobile : 94434 14477 98423 14477 email : jrjulus1970@gmail.com
Registered Valuer	District Panel Engineer	Chartered Engineer
• Plans	• Estimates	• Valuations
		• Stability Certificates
4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.		

S.C. No. 04/2026

Date: 12.01.2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : 12-305/1 (U.K.G. Block)
2. Location of the building : Thyrambika Vidya Mandir,
R.S.No. 467/9A, 467/9B, Cherupaloor,
Kulasekaram Post, Kanyakumari District.
3. Year of construction : 2018
4. Approximate cost of constn.
as per current rates : 60 Lakhs
5. Purpose for which building is
being used/ proposed to be used : School Building
6. Purpose for which building has
hitherto been used : School Building
7. Details of construction of building
 - a. Foundation : RCC Footing
 - b. Basement : RCC Plinth beam
 - c. Super Structure : RCC Columns with panel Brick Wall
 - d. Floor : PCC & Vitrified Tile floor finish
 - e. Roof : R.C.C. slab & beams
8. Period for which license
is required : 01.02.2026 to 31.01.2029 (3 years)
9. Number of persons to be
accommodated : 180 Nos.



J.R.Julius

District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Signature of the building owner

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION


1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 23.17 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1½:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1½:3 – 2.8 N/mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R. Julius
District Panel Engineer

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
D.No.12-305/1, U.K.G. Block, Thyrayambika Vidya Mandir, Cherupaloor, Kulasekaram Post, Kanyakumari District.	8 years	60 Lakhs	GF+1 only	Framed structure with paneled brick wall	School Building	01.02.2026 to 31.01.2029 (3 years)	180 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.

J.R. Julius
District Panel Engineer

FORM C

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 23.17 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R. Julius
District Panel Engineer

J.R.JULIUS , M.E., Ph.D., MIE, FIV,		Phone : 04652 - 261144 Mobile : 94434 14477 98423 14477 email : jrjulus1970@gmail.com
Registered Valuer	District Panel Engineer	Chartered Engineer
• Plans	• Estimates	• Valuations
		• Stability Certificates
4A1, St.Antony Street, Thalavaipuram, Nagercoil - 629 004.		

S.C. No. 08/2026

Date: 12.01.2026

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building : 12-305/5 (Block B)
2. Location of the building : Thyrambika Vidya Mandir (Senior Secondary Block),
R.S.No. 463/2A1B,2A2,2A3,3A,
467/4C2,4D,4E,4F,6D,6E,6F,7D,7E,7F,7G,8B
Cherupaloor, Kulasekaram Post, Kanyakumari District.
3. Year of construction : 2023
4. Approximate cost of constn.
as per current rates : 1050 Lakhs
5. Purpose for which building is
being used/ proposed to be used : School Building
6. Purpose for which building has
hitherto been used : School Building
7. Details of construction of building
 - a. Foundation : RCC Footing
 - b. Basement : RCC Plinth beam
 - c. Super Structure : RCC Columns with panel Brick Wall
 - d. Floor : PCC & Vitrified Tile floor finish
 - e. Roof : R.C.C. slab & beams
8. Period for which license
is required : 01.02.2026 to 31.01.2029 (3 years)
9. Number of persons to be
accommodated : 2040 Nos.



J.R.Julius
District Panel Engineer

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition/alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license, if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Signature of the building owner

FORM B

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

- | | |
|---|--------------------------|
| 1. Depth below ground level | : 2.40 m |
| 2. Nature of soil met with at foundation level | : Hard Gravel soil |
| 3. Pressure at Foundation | : 35.63 t/m ² |
| 4. Probable S B Capacity of the strata met with at foundation | : 45 t/m ² |

2. SUPERSTRUCTURE

- | | |
|--|---|
| 1. Maximum stress in the most critical section of masonry and concrete | : RCC 1:1 ¹ / ₂ :3 – 2.12 N/mm ² |
| 2. Nature of masonry and concrete and its safe permissible stress | : RCC 1:1 ¹ / ₂ :3 – 2.8 N/ mm ² |

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)



J.R.Julius
District Panel Engineer

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building	Age of building	The value of the building at the current rates	No. of Stories	Short Description	Certified purpose	Certified Period	No. of persons to be accommodated
D.No.12-305/5, Block B, Thyrayambika Vidya Mandir, Cherupaloor, Kulasekaram Post, Kanyakumari District.	3 years	1050 Lakhs	BF + GF+3 only	Framed structure with paneled brick wall	School Building	01.02.2026 to 31.01.2029 (3 years)	2040 Nos.

DECLARATION

I, J.R. JULIUS do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.



J.R.Julius
District Panel Engineer

FORM C

Form of CERTIFICATE OF STRUCTURAL STABILITY UNDER sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

1. Depth below ground level : 2.40 m
2. Nature of soil met with at foundation level : Hard Gravel soil
3. Pressure at Foundation : 35.63 t/m²
4. Probable S B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

1. Maximum stress in the most critical section of masonry and concrete : RCC 1:1¹/₂:3 – 2.12 N/mm²
2. Nature of masonry and concrete and its safe permissible stress : RCC 1:1¹/₂:3 – 2.8 N/ mm²

The structural soundness of the building has been verified by me with reference to I S I loading Standard 875 (Latest version) and other relevant I S CODE OF PRACTICE, and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A license may be granted for the period from 01.02.2026 to 31.01.2029 (3 years)


J.R. Julius
District Panel Engineer